





## 检验报告

## Fire Test Report

报告编号: 201310996 Report No. 201310996

送检单位名称: 艺格地毯 (上海) 有限公司

Company: EGE Carpets (Shanghai) Co., Ltd

产品名称型号: 编织地毯 厚度4mm

Product name: EPOCA 4mm thickness

检验类别:委托检验 Entrustment Inspection



国家防火建筑材料质量监督检验中心

Production name Epoca Thickness of sample 4mm

Applicant EGE Carpets (Shanghai) Co., Ltd Trade mark /

Producer EGE Carpets (Shanghai) Co., Ltd Type of inspection Entrustment Inspection

Submittion by EGE Carpets (Shanghai) Co., Ltd Sample collected basis /

Sample provided by EGE Carpets (Shanghai) Co., Ltd Sample collected date /

The place of sample collected / Sample receiving date 2013.07.26

The place of sample inspected Inspection center Inspection date 2013.08.02 - 2013.08.13

Quantity of sample 900mm\*250mm\*4mm, 10 pieces Number of sample 201313651

The inspection basis GB 8624-2012 Burning level of building materials and products

The inspection item Burning level BI ( C )

## The inspection result

After inspection, the product is able to meet the requirement of burning level of C-sl, tl According to GB 8624-2012, the burning level of this product is BI (C-sl, tl)

Issue date 2013.9.4

**Remark** This report is only responsible for this inspection.

## 国家防火建筑材料质量监督检验中心 检验结果汇总表

报告编号: 201310996

共3页第2页

JK II -	m J. 201010000					- KIE - K.
序号	检 验 项 目	检验方法	标准要求		检验结果	结 论
1	燃烧长度F <sub>s</sub> , mm	GB/T 8626-2007	С	≤150	60	B <sub>1</sub> 合格
2	临界辐射通量 <i>CHF</i> ,kW/m²	GB/T 11785-2005		≥4.5	5. 4	
3	产烟量,%.min	GB/T 11785-2005	s1	≤750	311	合格
4	产烟毒性,级	GB/T 20285-2006	t1	达到ZA <sub>3</sub>	ZA <sub>3</sub>	合格
	以	下	空		白	
	Inspection Item	Inspection Method	Required level I		nspection result	Conclusion
	The combustion length Fs,mm					
	Critical Radiant Flux CHF, KW/m2	2 *				
	Smoke production					
	Smoke toxicity					
		-				
备注						



Producer EGE Carpets (Shanghai) Co., Ltd

Address

Post code

Phone Fax

**Product description** 

The yarn of the product is 100% nylon

The thickness is 4mm

The address of inspection: 358 Xue Fu Road, Du Jiang Yan city, Si Chuan Province, CN

Before inspection After inspection