

TEST REPORT

Page 1 of 1	TEST NUMBER: 0247105
Egetaepper a/s	7231 HOMBER: 0247 103
	276.5 kg/s

TEST METHOD CONDUCTED	ASTM E662 Smoke Density (Flaming) Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials also referenced as NFPA 258
-----------------------	---



	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Highline 80/20 1400 ab
CONSTRUCTION	Cut Pile
BACKING	Attached Cushion
ENEDAL BRINGIBLE	

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

PREDRYING OF TEST SAMPLE CONDITIONING OF TEST SAMPLE TESTING CONDITION	24 Hours at 140° F	DITIONS and 50% Relative Humidity	
FURNACE VOLTAGE CHAMBER TEMPERATURE TEST MODE	118 V 95° F Flaming	IRRADIANCE CHAMBER PRESSURE	2.5 watts/sq cm 3" H ₂ O

AVERAGE SPECIFIC OPTICAL PENSITY	D (Dmc)	FLAMING	173
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			98
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	182.0	194.0	201.0
Time to Dm (minutes)	7.0	8.5	9.0
Clear Beam (Dc)	15.0	20.0	
Corr. Max Density (Dmc)	167.0		24.0
Density at 1.5 minutes		174.0	177.0
Density at 4.0 minutes	8.0	11.0	12.0
	91.0	98.0	106.0
Time to 90% Dm (minutes)	4.5	6.5	7.0
Specimen Weight (grams)	19.6	19.4	20.1
This sample BASSES He		17.4	20.1

^{*} This sample PASSES the requirements of 450 or less.

APPROVED BY:

Hary Coloury
This facility is accredited by the Na
Lab Code 100297. This accreditation

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place

Dalton, GA 30721

706-226-3283

Fax: 706-226-6787

protest@optilink.us



Professional Testing Laboratory Inc.

TEST REPORT

Page 1 of 1	TEST NUMBER	0247105
Egetaepper a/s	TEST (VOINDER).	024/103
		TEST NOMBER.

specific Optical D	noke Density (Non-Flaming) Standard Test Method fo al Density of Smoke Generated by Solid Materials als NFPA 258
2 Specific Objical D	al Density of Smoke Generated by Solid Mate



	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Highline 80/20 1400 ab
CONSTRUCTION	Cut Pile
BACKING	Attached Cushion

GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CONDI	ZNOIT	THE TOTAL OF THE STATE OF THE
PREDRYING OF TEST SAMPLE CONDITIONING OF TEST SAMPLE TESTING CONDITION	24 Hours at 140° F 24 Hours at 70° F and 50% Relative Humidity As Received		
FURNACE VOLTAGE CHAMBER TEMPERATURE TEST MODE	118 V 95° F Non-Flaming	IRRADIANCE CHAMBER PRESSURE	2.5 watts/sq cm 3" H ₂ O

AVERAGE MAXIMUM DENSITY CORRECTED (Dmc) NON-FLAMING		156 71	
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	147.0	170.0	162.0
Time to Dm (minutes)	14.5	12.5	12.3
Clear Beam (Dc)	4.0	3.0	3.0
Corr. Max Density (Dmc)	143.0	167.0	
Density at 1.5 minutes	34.0		159.0
Density at 4.0 minutes		37.0	33.0
	69.0	76.0	68.0
Time to 90% Dm (minutes)	10.2	9.2	9.2
Specimen Weight (grams)	19.4	19.5	19.8
The		17.0	17.0

^{*} This sample PASSES the requirements of 450 or less.

Day asbury

APPROVED BY:

พงใชด

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place

Dalton, GA 30721

706-226-3283

Fax: 706-226-6787

protest@optilink.us