# **TEST REPORT**

DATE: 05-31-2023 Page 1 of 1 TEST NUMBER: 0297609

DATE: OF CLECK	
CLIENT	Egetaepper a/s

12200-000 WWW. VALANCE VALOUE	ASTM E662 Smoke Density (Flaming) Standard Test Method for Specific
TEST METHOD CONDUCTED	Optical Density of Smoke Generated by Solid Materials also referenced as NFPA 258



- 10 T 10 T 10 T 10 T	DESCRIPTION OF TEST SAMPLE
IDENTIFICATION	Graphic Wool 1 100 LF
CONSTRUCTION	Cut Pile
BACKING	Attached Cushion

#### GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CON	IDITIONS	
PREDRYING OF TEST SAMPLE CONDITIONING OF TEST SAMPLE TESTING CONDITION	24 Hours at 140° 24 Hours at 70° F As Received	F and 50% Relative Humidity	
FURNACE VOLTAGE CHAMBER TEMPERATURE TEST MODE	118 V 95° F Flaming	IRRADIANCE CHAMBER PRESSURE	2.5 watts/sq cm 3" H <sub>2</sub> O

AVERAGE MAXIMUM DENSITY CORRECTED (Dmc) FLAMING AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			105
			46
The second secon	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	124.0	131.0	119.0
Time to Dm (minutes)	9.0	9.5	10.0
Clear Beam (Dc)	20.0	22.0	18.0
Corr. Max Density (Dmc)	104.0	109.0	101.0
Density at 1.5 minutes	2.0	3.0	4.0
Density at 4.0 minutes	45.0	43.0	51.0
Time to 90% Dm (minutes)	7.0	7.5	7.5
Specimen Weight (grams)	13.1	12.8	12.9

APPROVED BY:

NVILA COOR 100297 0

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shall not be used under any circumstance in advertising to the general public.



714 Glenwood Place Dalton, GA 30721

Dary asbury

706-226-3283

Fax: 706-226-6787

protest@optlink.us



### **Professional Testing Laboratory Inc.**

# **TEST REPORT**

DATE: 05-31-2023	Page 1 of 1	TEST NUMBER: 0297609
CLIENT	Egetaepper a/s	

	ASTM E662 Smoke Density (Non-Flaming) Standard Test Method for
TEST METHOD CONDUCTED	Specific Optical Density of Smoke Generated by Solid Materials also
	referenced as NFPA 258



	DESCRIPTION OF TEST SAMPLE	DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Graphic Wool 1100 LF		
CONSTRUCTION	Cut Pile		
BACKING	Attached Cushion		

### GENERAL PRINCIPLE

This procedure is designed to measure the specific optical density of smoke generated by the test specimen within a closed chamber. Each specimen is exposed to an electrically heated radiant-energy source positioned to provide a constant irradiance level of 2.5 watts/square cm on the specimen surface. Measurements are recorded through a photometric system employing a vertical beam of light and a photo detector positioned to detect the attenuation of light transmittance caused by smoke accumulation within the chamber. The light transmittance measurements are used to calculate specific optical density, a quantitative value which can be factored to estimate the smoke potential of materials. Two burning conditions can be simulated by the test apparatus. The radiant heating in the absence of ignition is referred to as the Non-Flaming Mode. A flaming combustion in the presence of supporting radiation constitutes the Flaming Mode.

	CONDI	TIONS	
PREDRYING OF TEST SAMPLE CONDITIONING OF TEST SAMPLE TESTING CONDITION	24 Hours at 140° F 24 Hours at 70° F an As Received	d 50% Relative Humidity	
FURNACE VOLTAGE CHAMBER TEMPERATURE TEST MODE	118 V 95° F Non-Flaming	CHAMBER PRESSURE	2.5 watts/sq cm 3" H <sub>2</sub> O

AVERAGE MAXIMUM DENSITY CORRECT	ED (Dmc)	NON-FLAMING	314
AVERAGE SPECIFIC OPTICAL DENSITY AT 4.0 MINUTES			84
	Specimen 1	Specimen 2	Specimen 3
Maximum Density (Dm)	315.0	327.0	309.0
Time to Dm (minutes)	14.5	15.0	14.0
Clear Beam (Dc)	3.0	2.0	4.0
Corr. Max Density (Dmc)	312.0	325.0	305.0
Density at 1.5 minutes	42.0	40.0	46.0
Density at 4.0 minutes	81.0	92.0	78.0
Time to 90% Dm (minutes)	11.5	12.0	11.0
Specimen Weight (grams)	13.0	12.7	12.8

APPROVED BY:

NVLAP

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the producttested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples testedand is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, Inc. shell not be used under any circumstance in advertising to the general public.



706-226-3283

Fax: 706-226-6767

Dary asbury